

Machine Name: Previous sample 2816496

Machine ID: 6637-1-20

STANDARD COOLANT ANALYSIS

Component Information Customer Information Sample Information Coolant: MPC Thermoguard Universal ELC5 Received: 7/27/2021 Jack Boilerman Coolant Chemistry: Report: 7/30/2021 **Great Lakes Fleet** Machine MFG: Sample No. 999-1-710 UNKNOWN 20338 Progress Drive Strongsville, OH 44149 Machine MOD: Analyst / Test: MMM / CLSTD Machine Criticality: Unknown Sample Source Rating: Unknown

PROBLEMS

Wrong Color Cloudy Appearance Observed Non-Magnetic Particles Observed

COMMENTS

Coolant has changed color. Coolant should match the color of the original manufacturer/product specifications. Probable causes of color change include improper coolant mixing, glycol deterioration, outside contaminants, and/or precipitation of inhibitors out of coolant. Coolant is cloudy. Coolant should be clear and bright. Possible cause of change in clarity include improper coolant mixing, glycol deterioration, outside contaminants, and/or precipitation. Non-magnetic particulate present in coolant. Possible causes include outside contamination entering cooling system and/or coolant chemical/inhibitor drop-out. Non-magnetic precipitate in coolant can cause the plugging of cooling system passages, which can lead to restriction of flow and over heating.

CUSTOMER NOTES

Sample Date Lab Number Hours on Engine	New Fluid	7/26/2021 3271963			I	Ι Τ	
Hours on Engine		3271963					
		32/1303					
		Unknown					
Hours on Fluid		Unknown					Normal
Condition		Marginal					Values
FLUID CONDITION							
Glycol % (R)		54.9					50.0
Freezing Point °C (R)		-44					< -30
Boiling Point °C (R)		109					> 100
pH ^(G)		7.8					7.0 - 11.0
OBSERVATIONS (analyst ra	ting) IWI-520						
Color		Non-standard					
Visual Clarity		Cloudy					Clear
Visible Foam		None					None
Visible Oil		None					None
Fuel Odor		None					None
Magnetic Particles		None					None
Non-Magnetic Particles		Slight					None
CONTAMINATION							
Specific Conductance (N)		551					< 6600
Total Dissolved Solids (N)		289					< 3400
Calcium (E)		-					< 60
Magnesium (E)		-					< 20
Hardness as CaCO ₃ (E)		-					< 300
Chloride ^(A)							< 75
Fluoride ^(A)							< 30
Sulfate (A)							< 300
DEGRADATION (mg/L) Ion	Chromatograp	hy IWI-500					
Glycolate (A)							< 1500
Acetate (A)							
Oxalate (A)							< 50
Formate (A)							< 250

The customer assumes sole responsibility for the application of and reliance upon results and recommendations reported by TestOil, whose obligation is limited to good faith performance. Samples tested as received.

Lab No. 3271963



Machine Name: Previous sample 2816496

Machine ID: 6637-1-20

STANDARD COOLANT ANALYSIS

Sample Date	New Fluid	7/26/2021				
Lab Number		3271963				
Hours on Engine		Unknown				
Hours on Fluid		Unknown				Normal
Condition		Marginal				Values
ADDITIVES (INORGANIC)						
Nitrate (A)						
Molybdenum ^(E)		8				
Nitrite (Test Kit) (J)		1600-3200				
Nitrite (A)						
Phosphate ^(A)						
Phosphorus ^(E)		20				
Boron (E)		13				
Silicon (E)		8				
Sodium ^(E)		542				
Potassium ^(E)		58				
SCA Number ^(U)		2.4				
ORGANIC ACID TECHNOLO	GY (mg/L) HPL	C IWI-510				
2-Ethylhexanoic Acid						
4-tBu-Benzoic Acid						
Adipic Acid						
Benzoic Acid						
Octanoic Acid	İ					
p-Toluic Acid	İ					
Sebacic Acid						
ВТ						
MBT						
TT						
WEAR (ppm) ICP Spectros	copy IWI-101					
Aluminum ^(E)		-				< 5
Copper ^(E)		-				< 5
Iron ^(E)		7				< 10
Lead ^(E)		-				< 5
Silver (E)		-				< 5
Tin ^(E)		-				< 5
Zinc ^(E)		-				< 10

Report Key: (-) Below detection limit, (A) mg/L - Ion Chromatography ASTM D5827 Mod, (E) ppm - ICP Spectroscopy IWI-101, (G) pH units IWI-142, (J) mg/L IWI-320, (N) uS/cm IWI-480, (R) Calculated from refractive index IWI-134, (U) Calculated from nitrite and molybdenum, (BT) Benzotriazole, (MBT) Mercaptobenzothiazole, (TT) Tolyltriazole



STANDARD COOLANT ANALYSIS

REPORT REFERENCE

Fluid Condition

Glycol concentration shows whether the right mix ratio is being employed (water to glycol); when lower than expected there is likely inadequate protection for the cooling system and engine, and when higher than expected there will be a loss of heat transfer capabilities. Freeze and Boiling Points are dependent on glycol% and hint at the expected operating temperature range. The pH of conventional coolants is typically higher than that of OAT or HOAT coolants, but both are typically alkaline (pH >7). If the coolant becomes acidic (pH <7) then there is a risk of corrosion, and if the coolant is more alkaline than expected it usually indicates mixing of coolants or over-concentration.

Observations

Color, clarity, and foam provide an overview of the physical appearance of the coolant, as any change will indicate likely degradation and/or contamination. Odors are checked for signs of contamination due to adverse conditions within the cooling system. Non-magnetic particles can appear for a number of reasons including a poor source of water (used to dilute coolant concentrate) or environmental ingression; magnetic particles are signs of corrosion, cavitation or defective electrical grounds.

Contamination

Conductivity increasing indicates contamination originating from the water supply, such as hardness (calcium and magnesium) and fluoride, or combustion gases; sudden changes may be the result of overdosing inhibitor or concentrate, or mixing with another coolant. The presence of these contaminants can lead to scale and/or corrosion within the cooling system.

Degradation

Glycolate indicates the primary breakdown of the glycol portion of the coolant which is generally caused by localized overheating or an air leak (i.e., combustion blow-by) within the system. Acetate, oxalate, and formate are all signs that degradation has progressed into a more severe, secondary stage of degradation.

Additives

The presence and concentration of additives will vary from one coolant to another and should be compared to the new fluid reference; the presence of additives not seen in the reference coolant indicates that mixing with another coolant has likely occurred, and may void the OEM warranty.

Organic Acid Technology

The presence and concentration of these additives will appear in some Extended Life Coolants (ELC) and should be compared to the new fluid reference.

Wear

Wear metals are most commonly signs of corrosion (driven by low or incorrect additives) or cavitation (driven by air leaks). They may also appear due to grounding faults, localized hot spots, or poor water source.